

EG-Baumusterprüfbescheinigung

EC type examination certificate

CE-0035BT0104Produkt-Identnummer
product identification no.

Anwendungsbereich <i>field of application</i>	EG-Gasgeräte-richtlinie (90/396/EWG) EC Gas Appliances Directive (90/396/EEC)
Zertifikatinhaber <i>owner of certificate</i>	Ferrol S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Vertreiber <i>distributor</i>	Lamborghini Calor S.p.A. Via Statale 342, I-44040 Dosso (FE)
Produktart <i>product category</i>	Boilers: Boiler without burner (3117)
Produktbezeichnung <i>product description</i>	Boiler without burner
Modell <i>model</i>	BIA 2...; VIT 2...; SEC 2...; EXA 2...
Bestimmungsländer <i>countries of destination</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FR, GB, GR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, SI, SK, TR
Prüfberichte <i>test reports</i>	type testing: K3222008T1 from 19.06.2008 (TRG) type testing: K3222008B3 from 20.06.2008 (TRG)
Prüfgrundlagen <i>basis of type examination</i>	EU/90/396/EWG (29.06.1990) DIN EN 303-1 (01.12.2003) DIN EN 303-3 (01.10.2004)
Aktenzeichen <i>file number</i>	08-0566-GEA

29.07.2008 Pie A-1/2

Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle
date, issued by, sheet, head of certification body

DVGW CERT GmbH - von der Deutschen Bundesregierung benannte und von der Europäischen Kommission offiziell registrierte Stelle für die Konformitätsbewertung von Gasgeräten

DVGW CERT GmbH - notified by the government of the Federal Republic of Germany and officially registered by the European Commission for conformity assessment of gas appliances

ZLS

ZLS-ZE-527/07

DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888

Telefax: +49 228 91 88-993

eMail: info@dvgw-cert.com

Installationsarten <i>installation codes</i>	Bestimmungsländer <i>countries of destination</i>	Bemerkungen <i>remarks</i>
B23	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FR, GB, GR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, SI, SK, TR	

Typ <i>type</i>	Technische Daten <i>technical data</i>	Bemerkungen <i>remarks</i>
BIA 2 30-90 I; BIA 2 30-90 V; VIT 2 30 R; VIT 2 30 CI; SEC 2 30 (B); EXA 2 27; EXA 2 32; EXA 2 27 B	heat output: 15,0...34,9 kW nominal heat input (Hi): 15,8...40,3 kW	
BIA 2 40-120 I; BIA 2 40-120 V; EXA 2 40 EXA 2 20	heat output: 32,5...46,5 kW nominal heat input (Hi): 35,4...53,6 kW heat output: 15,0...23,3 kW nominal heat input (Hi): 16,2...27,0 kW	
EXA 2 50	heat output: 40,5...58,1 kW nominal heat input (Hi): 43,9...66,9 kW	
EXA 2 60	heat output: 48,8...69,8 kW nominal heat input (Hi): 53,2...80,4 kW	
EXA 2 70	heat output: 57,0...81,4 kW nominal heat input (Hi): 62,1...93,7 kW	
EXA 2 80	heat output: 65,0...93,0 kW nominal heat input (Hi): 70,1...106,9 kW	

Verwendungshinweise / Bemerkungen

hints of utilization / remarks

The appliance categories and the gas supply pressures are according to the gas burner in use.