

TECHNIGAS

CERTIFICATO

CE/0461/E0989

Technigas, riconosciuto per Decreto Ministeriale del 5 maggio 1994 come organismo notificato per la messa in opera delle procedure previste dall'articolo 8 della Direttiva del Consiglio 90/396/CEE del 29 giugno 1990 concernente l'adattamento mutuo delle legislazioni degli Stati Membri in merito agli apparecchi a gas rilascia all'azienda

LAMBORGHINI CALOR S.p.A.

Via Statale 342

IT- 44040 DOSSO (FE) ITALY

il diritto di contrassegnare dal marchio CE le caldaie gas LAMBORGHINI

MEGAPREX N 80 - 90 - 100 - 120 - 150 - 200 - 250 - 300 - 350 - 400 -
500 - 620 - 750 - 850 - 950 - 1020 - 1200 - 1300 - 1400 - 1600 - 1800 -
2000 - 2400 - 3000 - 3500

MEGAPREX NK 250 - 300 - 350 - 400 - 500 - 620 - 750 - 850 - 950 - 1020
1200 - 1300

Paesi di destinazione : BE/ NL/ FR/ DE/ IT/ PT/ DK/ GR/ IE/ AT/ FI/ SE/ ES/ NO/ GB/ LU/
IS/ CH/ CZ/ HU/ CY/ EE/ LT/ LV/ MT/ PL/ SI/ SK

Detti apparecchi soddisfanno i requisiti essenziali e l'allegato II § 1 e 3 della detta Direttiva.

Fatto a Bruxelles, 12/09/2006



K. De Wit
Director



EC TYPE EXAMINATION CERTIFICATE

Annex II Paragraph I directive 90/396/EEC



<i>File number :</i>	E0989/5123/6	<i>Date of issue :</i>	31/07/2006
<i>ID number :</i>	0461AU0317		
<i>Fabricant</i>	ICI CALDAIE S.P.A.		
<i>Manufacturer:</i>	Via G. Pascoli 38		
<i>Fabrikant</i>	IT-37050 SANTA MARIA DI ZEVIO (VERONA)		
<i>Commerc.</i>	:	LAMBORGHINI CALOR S.p.A.	
<i>Marketed</i>		Via Statale 342	
<i>Gecommerc.</i>		IT -44040 Dosso (FE)	
<i>Marque commerc.</i>	:	LAMBORGHINI	
<i>Trade mark</i>			
<i>Handelsmerk</i>			
<i>Type</i>	MEGAPREX N 80 - 90 - 100 - 120 - 150 - 200 - 250 - 300 - 350 - 400 -		
<i>Model :</i>	500 - 620 - 750 - 850 - 950 - 1020 - 1200 - 1300 - 1400 - 1600 - 1800 -		
<i>Type</i>	2000 - 2400 - 3000 - 3500		
	MEGAPREX NK 250 - 300 - 350 - 400 - 500 - 620 - 750 - 850 - 950 - 1020		
	1200 - 1300		
<i>Genre d'appareil</i>			
<i>Kind of product:</i>		LOW-TEMPERATURE BOILER	
<i>Soort toestel</i>			
<i>Type d'appareil</i>			
<i>Appliance type:</i>		B ₂₃	
<i>Type toestel</i>			

The gas-fired heating boilers may be fitted with any forced draught burner which is CE-marked following the EN 676, if the operating characteristics of the boilers related to the rated heat and the back-pressure in the combustion chamber are situated within the burner's working range.

Countries of destination : BE/ NL/ FR/ DE/ IT/ PT/ DK/ GR/ IE/ AT/ FI/ SE/ ES/ NO/ GB/ LU/ IS/ CH/ CZ/ HU/ CY/ EE/ LT/ LV/ MT/ PL/ SI/ SK

Normative references: EN 303-1 edition 01/1999
EN 303-3 edition 09/1998

K. DE WIT
K. DE WIT
DIRECTOR